

Specifications for Ductable Air Conditioners

The following features must be standard part of the system and documentary evidence of the same should be provided along with technical bid.

| S. No. | Indoor Unit | | |
|--|------------------------|------------------------|--|
| 1 | Rated Cooling Capacity | 5 Ton | |
| | | 17,600 Watt | |
| | | 60,000 Btu/h | |
| 2 | Normal Air Quality | .94 m ³ /s | |
| | | 2000 CFM | |
| 3 | Power Supply | 230-1-50 (V-ph-Hz) | |
| 4 | Fan | Type | Direct Drive DIDW forward curved centrifugal fan |
| | | Quantity | 2 |
| | | Discharge | Horizontal/Vertical |
| 5 | Fan Motor | Type | Permanent Split Capacitor |
| | | Quantity | 2 |
| 6 | Overall Size | Width | 63.3cm |
| | | Depth | 46cm |
| | | Height | 120cm |
| 7 | Net weight | 65 Kg | |
| 8 | Refrigerant | R-22 | |
| Connecting Pipe and Connecting Cable must be mentioned | | | |
| S. No. | Outdoor Unit | | |
| 1 | Rated cooling capacity | 5Ton | |
| | | 17500 Watt | |
| | | 60,000 Btu/h | |
| 2 | Fan Motor | 0.28 m ³ /s | |
| | | 600 CFM | |
| 3 | Power Supply | 230-1-50 (V-ph-Hz) | |
| 4 | Fan | Type | Direct Drive DIDW forward curved centrifugal fan |
| | | Quantity | 2 |
| | | Discharge | Horizontal/Vertical |
| 5 | Compressor | Type | Permanent Split Capacitor |
| | | Quantity | 2 |
| 6 | Overall Size | Width | 120 cm |
| | | Depth | 24 cm |
| | | Height | 57 cm |
| 7 | Net weight | 20 Kg | |
| 8 | Refrigerant | R-22 | |
| Connecting Pipe and Connecting Cable must be mentioned | | | |

Site of Installation

For site visit where Air Conditioner needs to be installed please contact

Dr. Kaustuv Datta, Department of Genetics, UDSC.

Tel: 24119810 Email: kdatta@south.du.ac.in

Eligibility Criteria

- Bidder should be Manufacturer/ Authorized Partner/ Reseller of the manufacturer and a Letter of Authorization from manufacturer for the same and specific to the tender should also be enclosed. The bidder should also be the Authorized Service Provider.
- The Bidder shall provide the Registration number of the firm along with the LST/ CST/ WCT No. and the PAN Number issued by the concerned authorities.

- Separate technical and price bid should be uploaded.
- Technical Bid must contain a Technical Compliance sheet. Technical compliance sheet must have the page number of a published catalogue/operating manual/manufacture website as proof for compliance with the instrument and accessories for each technical points. Relevant copies of catalogue/operating manual/manufacture website pages that have been listed as proof should be attached.
- The bidder must not be blacklisted by Delhi University or any other government institution. A Certificate or undertaking to this effect must be submitted.

No Commitment to Accept Lowest or Any Tender

- University of Delhi shall be under no obligation to accept the lowest or any other offer received in response to this tender notice and shall be entitled to reject any or all offers. University of Delhi will not be obliged to meet and have discussions with any vendor, and or to listen to any representations.

Warranty /Comprehensive Maintenance

- Machine should be warranted for minimum 12 months from the date of installation.
- Installation and commissioning to be completed up to the satisfaction level of the technical purchase committee followed by training and handling by the bidders

Price quotation

- F.O.R. UDSC price (INR/FC) to be quoted which includes, custom duty & clearance as well as transportation charges to site of installation. CDEC/IGST certificate will be provided if requested.
- Price Bids should contain the prices, terms of delivery, sales, payment terms etc.
- Price quotation should include cost for installation such as carpentry or masonry work
- Price bid should also include site preparedness i.e. any minor civil/electrical/plumbing work required for installation/smooth operations during warranty period.
- Price quotation must include removal of any installed equipment if required.
- Payment will be made against successful installation. Advance payment will NOT be made.
- Price quotation must be valid for 6 months.


Published Date: 17-01-2019 (10:00 Hrs)

Bid Document Download Start Date: 18-01-2019 (11:00 Hrs)

Bid Submission Start Date: 19-01-2019 (10:00 Hrs)

Bid Submission End Date: 09-02-2019 (17:00 Hrs)

Bid Opening Date: 11-02-2019 (11:00 Hrs)



Kaustuv Datta

KAUSTUV DATTA, Ph.D
Assistant Professor
Department of Genetics
University of Delhi South Campus
New Delhi-110021

All the relevant documents related to tender can be found on CPPP portal